



NOTES:

1. Valve size and type to be specified by the Design Engineer and approved by the City Engineer.
2. Valve box assembly is to be in accordance with *Beaverton Standard Dwg 615* or as approved by the City Engineer.
3. Paint bollard yellow.
4. Exact location of shutoff valve and bollard to be determined in the field by the City Engineer.
5. Galvanized pipe is permitted only on the outlet side of the combination valve.



City Of Beaverton

ENGINEERING DEPARTMENT

UTILITIES ENGINEER
David A. Winship, P.E.

DATE
6 - 10 - 04

2" COMBINATION AIR AND VACUUM VALVE

DRAWN BY
JR - CPD

DRAWING NO.
636